

Village of Wheeling - Sanitary Sewer Service Line / Cleanout Requirements

- 1) A plumbing permit is required if work is within 5 feet of the building. Contact Community Development at 847-459-2620.
- 2) All work must be done by a licensed sewer or plumbing contractor who must provide the Village with a copy of their State of Illinois Department of Public Health registration license.
- 3) Install 6" PVC tee with a sweep towards the street.
- 4) Use non-shear couplings to make connections to dissimilar pipe materials.
- 5) PVC cement and primer required for PVC/PVC connections.
- 6) Extend clean out to grade, cap as needed.
- 7) In replacing a service line – SDR 26, Schedule 40 or DIP is required.
- 8) All sewer repairs must be bedded and covered in ¾" or CA-7 compacted wash gravel.
- 9) A \$1,000 cash bond shall be required at permit issuance (contractor doing the work shall provide this). The bond shall be refunded 4 to 6 weeks after inspection and approval by the Engineering or Plumbing Inspector of the restoration area.
- 10) Contractors must make use of a 5 ½" cutter to ensure a clear service line.
- 11) Upon completion of repairs, but before backfilling, an inspection by the Engineering or Plumbing inspector is required.
- 12) The use of a TV sewer camera may be used to verify that the service line is clear.