



- NOTES:**
1. CLASS 52 DUCTILE IRON PIPE OR SDR 26 PVC MAY BE USED UNLESS OTHERWISE STATED
 2. CAPACITY SHOULD BE AT LEAST 1000 GALLONS. DIMENSIONS MAY VARY DEPENDING ON CAPACITY.
 3. 4" DIP MAY BE USED WITH PRIOR APPROVAL
 4. WATER TIGHT LIDS ARE REQUIRED



VILLAGE OF WHEELING
 ENGINEERING DIVISION
 2 COMMUNITY BOULEVARD
 WHEELING, IL 60090
 WWW.WHEELINGIL.GOV

GREASE BASIN STANDARD

VILLAGE OF WHEELING
 SPECIFICATIONS AND DETAILS

REVISIONS	
S.W.	02-27-03 PER COMMENTS
C.J.C.	03-07-07 INSP. COMMENTS
C.J.C.	11-27-07 AUTOCAD FILE
K.A.G.	1-23-20 ADDED NOTES

DETAIL NO.

SAN-2