



NOTE:

1. NOTIFY P/W UTILITY DIVISION 48 HOURS PRIOR TO START OF CONSTRUCTION AT (847) 279-6900.
2. COORDINATE WATER SHUTDOWN WITH THE PUBLIC WORKS DEPARTMENT, EXCAVATE AREA AND DISCONNECT HYDRANT LEAD, PLATE TEE, BLOCK AND RESTRAIN.
3. RETURN HYDRANT, AUXILIARY VALVE AND BOX TO PUBLIC WORKS DEPARTMENT.
4. BACKFILL AND COMPACTION PER THE VILLAGE OF WHEELING'S STANDARD.
5. THE PLUG SHALL BE MECHANICAL JOINT.
6. ALL FASTENER HARDWARE (i.e., NUTS, BOLTS, AND WASHERS) ASSOCIATED WITH THE PLUG SHALL BE STAINLESS STEEL.



VILLAGE OF WHEELING
 ENGINEERING DIVISION
 2 COMMUNITY BOULEVARD
 WHEELING, IL 60090
 WWW.WHEELINGIL.GOV

FIRE HYDRANT ABANDONMENT STANDARD

| | | |
|---|-----------|-------------------------|
| VILLAGE OF WHEELING SPECIFICATIONS AND DETAILS | REVISIONS | |
| FILE LOCATION | R.A. | 8-19-99 |
| T:\ENGINEERING\STANDARDS | S.W. | 3-2-00 AUTOCAD FILE |
| | C.J.C. | 9-11-06 AUTOCAD FILE |
| | S.W. | 01-24-07 PER COMMENTS |
| | K.A.G. | 11-21-16 CHANGE PHONE # |

| |
|------------|
| DETAIL NO. |
| W-2 |